REFERENCES:

[1] A. Molino et al (2001), New approaches to model electric demand in Aluminium industry.

[2] A.P. Agalgaonkar et al (2009), Open loop Response Characterization of an Aluminium Smelting Plant for Short Time Interval Feeding, Copyrights Material, IEEE.

[3] A.R. Prasad et al (1991), An Active Power Factor Correction Technique for Three Phase Diode Rectifiers, IEEE Transactions on Power Electronics, Vol.6, No.1.

[4] Ali Mirbod and Ahmed El-Amawy (1986), A General Purpose Microprocessor Based Control Circuit for a Three Phase Controlled Rectifier Bridge, IEEE Transactions on Industrial Electronics, Vol.IE 33, No.3.

[5] Anthony Siebert et al (2002), AC to DC Power Conversion Now and in the future, IEEE Transactions on Industry Applications, Vol.38., No.4.

[6] B.Singh and S.Gairola (2006), A 36 Pulse AC-DC Convertor for Line Current Harmonic Reduction, In Proc IEEE Conf. Power Electronics-New Delhi India, PP, 1-6 Paper 4B-29.

[7] Bhim Singh et al (2007), Multipulse AC-DC Converters for Improving Power Quality, IEEE Transactions on Power Electronics,Vol.23., No.1.

[8] C. Boon sang and V. Kinnares (2001), Analysis of Harmonic for 12 Pulse Convertor under Unbalanced Voltage Operation due to Lightning Related Voltage Sags and Short Interruption,"InProc.IEEE Conf. Power Eng. Soc.01, Vol.3., PP 1009-1014.

[9] C.T Pan and T.C. Chen (1994), Step Up/Down Three Phase AC to DC Converter with Sinusoidal Input Current and Unity Power Factor, IEE Proc. Electr. Power Appl. Volume 141., No.2.

[10] Carlos A. Mufioz and Ivo Barbi (1999), A New High Power Factor Three Phase AC-DC Convertor:Analysis Design and Experimentation, IEEE Transactions on Power Electronics,Vol.14., No.1.

[11] Christopher K. Duffey and Ray. P. Stratford (1989), Update of Harmonic Standard IEEE 519:IEEE Recommended Practices and Harmonics for Harmonic Control in Electric Power Systems,"IEEE Transactions on Industry Applications,Vol.25, No.6.

[12] F. Masawi et al (2007), Analysis of the performance of an African joint venture company established for the transport of bulk power from Eskom South Africa to Swaziland, Mozambique and the Mozal aluminium smelter in Maputo. IEEE 1-4244-1298-6/07.

[13] Francois Cluzel et al (2011), Towards parametric environmental profiles of complex industrial systems in preliminary design stage. ASME 2011-IDETC/CIE 2011, Washington, DC.

[14] Frederick Blaabjerg et al (2005), The Future of Electronics Power Processing and Conversion,"IEE Transactions on Power Electronics, Vol.20, No.3.

[15] Frederick Hoadley et al (2007), Comparison of AC to DC Rectifier topologies Operating on Various Power Distribution Networks." Copyrights Material IEEE Paper No PCIC-1.

[16] G.K. Dubey (1983), Classification of Thyristor Commutation Methods, IEE Transactions on Industry Applications, Vol-IA-19., No.4.

[17] G.N. Bathurst et al (2001), A Harmonic Domain Solution for Systems with Multiple High Power AC/DC Converters, IEEEProc-Generation-Transmission Distribution, Vol.148., No.4.

[18] Georges-Emile April and Guy Olivier (1985), A Novel Type 12 Pulse Converter,"IEEE Transactions on Industry Applications, Vol-IA-21., No.1.

[19] Gerson H. Pfitscher (1983), A Microprocessor Based Synchronization Scheme for Digitally Controlled Three Phase Thyristor Power Converters, IEEE Transactions on Industrial Electronics,Volume IE-30., No.4.

[20] Guy Olivier et al (1981), Microprocessor Controller for a Thyristor Converter with Improved Power Factor, IEEE Transactions on Industrial Electronics and Control Instrumentation,Vol. I ECT-28., No.3.

[21] Guy Olivier et al (1995),"Novel Transformer Connection to Improve Current Sharing in High Current D.C. Rectifiers,"IEEE Transactions on Industry Applications, Vol.31, No.1.

[22] J.L Aguero et al (1999), Aluminium plant, Load modeling for stability studies.” In PROC 1999 IEEE power engineering society summer mitting. pp 1330-1335.

[23] M. Wiestner and Baden (2007), Captive power plant-smelter interface with black out protection for increased power plant efficiency. Aluminium technology—9/2007

[24] Michael A. Slomin et al (1984), Stability of Controlled Rectifiers: Phenomena and Experiment,”IEEE Transactions on Industry Applications, Vol. IA -20., No.4.

[25] MuammerErmis and Adnan Acik (2004), Power Quality Solutions for 12 Pulse Smelters in ETI Aluminium Works,”IEEE Transactions on Industry Applications, Vol. 40., No.6.

[26] Patrick Pollock and Christopher Duffey (1998), Power Quality and Corrective Action in an Aluminium Smelter,”Copyright Material IEEE.

[27] Ray. P. Stratford (1981), Analysis and Control of Harmonic Current in Systems with Static Power Converters, IEEE Transactions on Industry Applications, Volume IA-17, No.1.

[28] Ricardo Fuentes and Luis neira (2007), Effects of layout on current distribution in paralleled thyristors of high current rectifiers, copyright material IEEE, paper no. PCIC-2007-21.

[29] S. Choi et al (1999), A new 24 Pulse Diode Rectifier for High Voltage and High Pressure Applications,”In Proc. IEEE PESC 99., PP-169-174.

[30] S. Perera et al (2000), Investigation in to the Harmonic Behaviour of Multipulse Converter System in Aluminium Smelter. AUPEC-2000, Queensland University of Technology-ITEE.

[31] Shayong Yang et al (2011), An Industry Based Survey of Reliability in Power Electronics Converters,”IEEE Transactions on Industry Applications, Vol.47. No.3. May /June-2011.

[32] Sjoerd W.H. Dehaan (1986), Analysis of the Effect of Source Voltage Fluctuations on the Power Factor in Three Phase Rectifiers”. IEEE Transactions on Industry Applications, Vol.IA-22., No.2.